



Carrier HVAC Equipment (Hangzhou) Co., Ltd.
NO.181, Weiken Street, Baiyang Block, Hangzhou Qiantang Area,
Zhejiang Province, the People's Republic of China
TEL:+86-571-26892333 FAX:+86-571-26892388

Mini-SMMS-e_24082901 -1/2

DECLARATION OF CONFORMITY

We, Quality Assurance Division of

Carrier HVAC Equipment (Hangzhou) Co., Ltd.

NO.181, Weiken Street, Baiyang Block,

Hangzhou Qiantang Area, Zhejiang Province, the People's Republic of China

declare under our sole responsibility that the product,

Product name: TOSHIBA AIR CONDITIONER

Type: MiNi-Super Modular Multi Systems (MiNi-SMMS-e)

Brand name: TOSHIBA

Models name: MCY-MHP0806HS8-E, MCY-MHP1006HS8-E

Country of origin: China

To which this declaration relates is in conformity with the following standards or other normative documents;

EN 60335-1:2012+A11:2014+A13:2017+A1:2019+A2:2019+A14:2019+A15:2021+A16:2023

EN IEC 60335-2-40:2023+A11:2023

EN 62233:2008: Electromagnetic fields

EN IEC 55014-1:2021: EMC Requirements

EN IEC 55014-2:2021: EMC Requirements

EN IEC 61000-3-11:2019: EMC Requirements

EN 61000-3-12:2011: EMC Requirements

EN IEC 63000:2018: Technical documentation for the assessment of RoHS

Following the provisions of the EU Council Directives;

2006/42/EC : Machinery Directive

2014/30/EU : EMC Directive

2009/125/EC : Energy-related Products and EU/2017/1369 : Energy Labelling Framework Directives

2011/65/EU : Restriction of the use of certain hazardous substances (RoHS)

Note: This declaration becomes invalid if technical or operational modifications are introduced without the manufacturer's consent.

Manufacturer:

Signature

Hiroyuki Takeuchi

Deputy General Manager

Quality Assurance Dept

Carrier HVAC Equipment (Hangzhou) Co., Ltd.

NO.181, Weiken Street, Baiyang Block, Hangzhou Qiantang Area,

Zhejiang Province, the People's Republic of China

Aug 29th, 2024

Hiroyuki Takeuchi

29th Aug 2024.

Attached sheet:

Mini-SMMS-e_24082901 -2/2

Models:

Outdoor unit

	Model Name	Manufacturer	EMC	MD	ErP	RoHS
Outdoor unit	MCY-MHP0806HS8-E MCY-MHP1006HS8-E	Carrier HVAC Equipment (Hangzhou) Co.,Ltd.	Complied	Complied	Lot6/21	Complied

Category test report:

Test report	Issued by	Report no.
CB	TUV	CN24M58V 002
MD	TUV	CN24MZO3 002
EMC	TUV	50302754 007

The year in which the CE Marking was affixed: Please see serial number indicated in nameplate.