



Carrier HVAC Equipment (Hangzhou) Co., Ltd.
NO.181, Weiken Street, Baiyang Block, Hangzhou Qiantang
Area, Zhejiang Province, the People's Republic of China
TEL:+86-571-26892333 FAX:+86-571-26892388

Document no. 24090401 -1/2

DECLARATION OF CONFORMITY

We, Quality Assurance Division of

Carrier HVAC Equipment (Hangzhou) Co., Ltd.

NO.181, Weiken Street, Baiyang Block,

Hangzhou Qiantang Area, Zhejiang Province, the People's Republic of China

Declare under our sole responsibility that the product,

Product name: Heat recovery ventilation unit with DX Coil

Brand name: TOSHIBA

Type: Concealed microcomputer control type

Models: Please refer to models table.

Country of origin: China

To which this declaration relates is in conformity with the following standards or other normative documents;

IEC 60335-2-40:2018 in conjunction with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/AMD2:2016

EN IEC 60335-2-40:2023+A11:2023 used in conjunction with

EN 60335-1: 2012+AC:2014+A11:2014+A13:2017+A1:2019+A14:2019+A2:2019+A15:2021+A16:2023

And EN 62233:2008+AC:2008

EN 62233:2008: Electromagnetic fields

IEC 62233:2005

EN 55014-1:2017+A11:2020: EMC Requirements

EN 61000-3-2:2014: EMC Requirements

EN 61000-3-3:2013+A1:2019: EMC Requirements

EN 55014-2:2015: EMC Requirements

EN 378-2: 2016: Safety Regulation

EN IEC 63000:2018: Technical documentation for the assessment of RoHS

Following the provisions of the EU Council Directives;

2014/30/EU: Electromagnetic Compatibility

2006/42/EC: Machinery Directive (MD)

2009/125/EC: Energy-related Products

2011/65/EU: Restriction of the use of certain hazardous substances (RoHS)

Note: This declaration becomes invalid if technical or operational modifications are introduced without the manufacturer's consent.

Manufacturer:

Signature

Hiroyuki Takeuchi

Deputy General Manager, Quality Assurance Dept

Carrier HVAC Equipment (Hangzhou) Co., Ltd.

Hiroyuki Takeuchi
4th Sep 2024.

NO.181, Weiken Street, Baiyang Block,
Hangzhou Qiantang Area,
Zhejiang Province, the People's Republic of China
Sep 4th, 2024

Models: (*"Italic": The year in which the CE marking was affixed.*)

	Model Name	Manufacturer	EMC/MD	ErP	RoHS
Heat recovery ventilation unit with DX Coil	MMD-UPV0501HY-E MMD-UPV0801HY-E MMD-UPV1001HY-E	Carrier HVAC Equipment (Hangzhou) Co.,Ltd.	Complied/ Complied	Lot11 Lot6/21	Complied

Referred test report:

Test report	Issued by	Report no.
CB	TUV	TH24B7ZT 002
MD	CJC	ME-6580 ME-6581
EMC	e-OHTAMA	T-2400226-01
EMF	e-OHTAMA	T-2400226-02

The year in which the CE Marking was affixed: Please see serial number indicated in nameplate.